

CERTIFICATE

No 270-092/09

Product

External thermal insulation composite system **MIRATHERM**, with acrylic rendering.

Manufacturer /Supplier

Mira Ehitusmaterjalid OÜ (Reg code 10346900), Segu 8, 76505 Saue, Harjumaa, ESTONIA.

Product description and field of application

Product consists of next components: adhesive MIRA 5100 (5300); insulation material: EPS or mineral wool;armouring MIRA 5300 + alkali-resistant armouring mesh; bonding primer Mira Guarz Grund 5335; mineral finishing plaster MIRA 5360 Reibe (5370 Kratz), thickness 2,0mm.

Field of application: Facades renovation and thermal insulation for buildings.

Classification standard

EN 13501-1:2007 "Fire classification of construction products and building elements. Part 1: Classification using test data from reaction to fire tests".

Classification

According to standard EN 13501-1:2007 the product **external thermal insulation composite system MIRATHERM , with acrylic rendering** in relation to its reaction to fire behaviour are classified:

B-s1, d0.

Basis

1. Assessment report No AK-15-09 (Inspecta Estonia OÜ);
2. Decision of the Board No 16/05/09, 28.05.2009.

KOOPIA

Appertaining documents

1. Quality supervision registers R2.
2. Installation manual.

Quality control


Quality control is carried out according to Quality supervision contract No KJL-101/2009.

Certificate validity conditions

Present certificate is valid from 28.05.2009 until 28.05.2014 provided the regular quality control is performed in time and adequate note is fixed in register. Current certificate is not certificate of conformity according to the construction product directive 89/106/EEC, and doesn't give authority to affix CE marking to the product.



Accredited
PC015


Janek Neltsas
Member of the Board